



Alarm Monitoring Standard

Standard

Richland Municipal Code Title 20
2018 International Fire Code, Section 904.3.5
National Fire Protection Association (NFPA) 72

Practice

All fire alarm and automatic sprinkler alarm messages shall be relayed from the approved alarm monitoring company to the Southeast Communication (SECOMM) dispatch center before any other agency or individual is notified. Fire alarm and sprinkler system "trouble" or "supervisory" type messages, unless approved by the Fire Code Official, shall not report to the SECOMM dispatch center, per RMC 20.05.010C

Guide

The building owner/tenant will determine the approved agency that provides monitoring.