



Elevator Standard

Standard

Richland Municipal Code Title 20 Chapter 20.09

Practice

This standard shall be applied to new passenger elevators in every occupancy.

- All passenger elevators shall have a minimum interior dimension of 80" in width and 51" in depth.
- The minimum door opening width shall be 42".
- A side-opening door is preferable to a center opening door.

Exceptions:

- R3 occupancies
- Occupancies with exterior ramped access to an approved walkway for all floors served by the elevator.