



NOTES:

1. DRAIN HOLE TO BE INSTALLED AFTER PRESSURE TEST OF WATER MAIN.
2. RIGID SUPPORT REQUIRED BETWEEN CAP AND 90 DEG BEND
3. BLOW-OFF PIPE SIZE FOR PIPES >12" MUST BE CALCULATED TO INSURE REQUIRED FLUSHING VELOCITY.

WATER LINE SIZE	THRUST BLK SIZE*	GALV. PIPE SIZE
6"	1.9 SF	2"
8"	3.3 SF	2"
10"	5.4 SF	3"
12"	7.7 SF	3"

*BEARING AREA AGAINST TRENCH WALL



TEMPORARY BLOW-OFF ASSEMBLY

PUBLIC WORKS ENGINEERING

APPR. BY: SAW

DATE: 01.24

DRAWN BY: JLR

DWG: W13A

CAD FILE: 2024_W13A_01_2024