



NOTES:

1. SET JUNCTION BOX AT 24" FROM STREET LIGHT FOUNDATION OR AS APPROVED BY ENGINEER. SET BOX AT AN ELEVATION SUCH THAT THE TOP OF THE BOX COVER IS APPROXIMATELY 2" ABOVE FINISHED GRADE UNLESS BOX IS TO BE SURROUNDED BY ASPHALT OR CONCRETE. SET BOX LEVEL WITH AND PARALLEL TO STREET.
2. SWEEP CONDUIT UP INTO JUNCTION BOX A MINIMUM OF 6". INSTALL BELL ENDS OR BUSHINGS ON ALL EXPOSED CONDUIT ENDS IN JUNCTION BOX.
3. ALLOW SUFFICIENT SLACK IN CONDUCTORS SUCH THAT SPLICES MAY BE REMOVED A MINIMUM OF 36" FROM SPLICE BOX.
4. A HEAVY DUTY LID SHALL BE USED FOR SUCH OCCASIONS WHERE THE JUNCTION BOX IS LOCATED IN VEHICULAR TRAFFIC BEARING AREAS SUCH AS DRIVEWAYS OR SIDEWALKS.



## JUNCTION BOX & FOUNDATION DETAILS

PUBLIC WORKS ENGINEERING

APPR. BY: PKR

DATE: 11.21

DRAWN BY: LD

DWG: SL4

CAD FILE: 2015\_SL4\_11\_2021