



THE ON-SITE SOILS MAY BE USED FOR COMPACTED TRENCH BACKFILL.

PIPE BEDDING MATERIAL SHALL CONFORM TO THE WSDOT/APWA STANDARD SPECIFICATIONS 9-03.9(3) TOP COURSE

ALL PIPE BEDDING SHOULD BE WRAPPED IN A NON-WOVEN GEOTEXTILE FABRIC. THE GEOTEXTILE SHALL HAVE A NOMINAL WEIGHT OF AT LEAST 6 OUNCES PER SQUARE YARD. THE GEOTEXTILE SHALL EXTEND ACROSS THE BOTTOM OF THE TRENCH, UP THE SIDES OF THE TRENCH, AND SHALL OVERLAP AT LEAST 2 FEET ON THE TOP OF THE TRENCH.



GROUND WATER TRENCH DETAIL

PUBLIC WORKS ENGINEERING

APPR. BY: PKR

DATE: 12.2010

DRAWN BY: LD

DWG: U3

CAD FILE: 2012_U3_12_2010