



NOTES:

1. SEE STANDARD DETAIL W15 FOR BOLLARD POST REQUIREMENTS. CONTACT ENGINEER FOR PLACEMENT LOCATION. 5'x10' CONCRETE SIDEWALK TO BE PLACED AROUND HYDRANT AS DIRECTED BY ENGINEER.
 2. IF FIRE HYDRANT IS MORE THAN 50' AWAY FROM THE WATER MAIN, INSTALL 8" LINE & VALVE WITH 8" X 6" REDUCER AT HYDRANT.
 3. LOCATE FIRE HYDRANT 2' BEHIND CURB WHERE NO SIDEWALK IS PRESENT.
 4. NO EXTENSIONS ALLOWED ON NEW INSTALLATIONS.
 5. SEE STANDARD DETAIL W12 FOR TRACING WIRE INSTALLATION ON PVC MAIN LINES.
- * STRIP INSULATION FROM LAST 12" OF THE WIRE AND BEND OVER LIP OF BOTTOM BOX.



FIRE HYDRANT DETAIL

PUBLIC WORKS ENGINEERING

APPR. BY: PKR

DATE: 03.2020

DRAWN BY: EY

DWG: W14

CAD FILE: 2014_W14_03_2020